



TITLE R-402, KTS REACTOR

UNIT PROCESS

P&ID# 402

LOCATION FRESNO, CA



PRESSURE VESSEL DATA

MANUFACTURER	TKS, INC.	
SERIAL NO	08037R402	
NATIONAL BOARD #	106	
DATE OF CONST.	2009	
MAWP	50 PSIG	
MAWT	375°F	
DIAMETER	11'-0"	
HT OR LENGTH (S.S.)	10'-0"	
SHELL	THICKNESS	.375"
	MATERIAL	SA-240-T304L
	LONG SEAM	YES
HEADS	TYPE	2:1
	THICKNESS	.500"/.375"
	MATERIAL	SA-240-T304L
CODE STAMP (Y OR N)	Y	
RADIOGRAPHY	NONE	
NOZZLE FLANGE RAT.	150#	



\* BLANKET INSULATION.

INSPECTED BY DAC 03/16

UT'D BY JBC, LGM DATE 03/16



R-402  
KTS REACTOR

CLIENT LOGO HERE

REVISED BY - DATE -

DRAWN BY JEF (DLR) DATE 11/11

NO. FRE - 1.1

FRE001A.DWG